



88 Empire Drive • St. Paul, Minnesota • 55103  
(651) 642-1150 • fax (651) 642-1239

## VOC Content Test Certificate

Friday June 19, 2009

Supplier: Hilti Entwicklungsgesellschaft mbH  
BU Chemical Anchors  
Hiltistrasse 6  
86916 Kaufering  
GERMANY

Sample Description: Hilti HVU-TZ

Date tested: June 2009

Test Method: SCAQMD method 304-91 Determination of Volatile Organic Compounds (VOC) in Various Materials as referenced by South Coast Air Quality Management District (SCAQMD) Rule 1168. The values also comply with the requirements of EPA test method #24.

Test Data:

Specification	Product
<b>LEED 2009 (LEED 3.0)</b> <b>LEED 2.2</b> IEQ-4.1: Low-Emitting Materials – Adhesives and Sealants	<b>Hilti HVU-TZ</b>
<b>Green Building Council of Australia</b> Green Star Office Design 3.0, IEQ-13 Green Star Office Design 2.0, IEQ-13 Green Star Office Interiors 1.1, IEQ-11	
<b>Multipurpose Construction Adhesives;</b> <b>VOC Limit: 70 g/L</b>	<b>Product contains: 39 g/L of VOC</b>

---

William Welbes  
Vice President of Laboratory Operations

Allen Noreen, Ph.D.  
Technical Director