

Confirmation

LEED

On 10 November 2015, Eurofins Product Testing A/S received a sample of a chemical anchor with the product name:

HIT-RE 100

supplied by

Hilti Entwicklungsgesellschaft GmbH

The sample was supplied as being representative of the manufactured product, and it has been tested as "Multipurpose Construction Adhesive" in accordance with the relevant ISO 16000, CDPH, ISO 11890-1, ASTM D2369 and EPA method 24 testing standards (See test report no. 392-2015-00360101_H and 392-2015-361601).

The test results of the tested adhesive indicate that the product qualifies for LEED v4 and LEED 2009 specifications on VOC emissions and VOC content by complying with:


VOC emissions specifications in LEED EQ credit "Low-emitting products":

- The requirements of CDPH-IAQ (California Department of Public Health); and a TVOC below 0.5 mg/m³ in both office and class room.

VOC content specifications in LEED EQ credit "Low-emitting products":

- The requirements of SCAQMD rule 1168 (2005)

8 December 2015



Thomas Bjerring
Analytical Service Manager



Janne R. Norup
Chemist