

# Confirmation

## LEED

On 13 March 2017, Eurofins Product Testing A/S received a sample of a chemical anchor with the product name:

**HVU2**

supplied by

**Hilti Entwicklungsgesellschaft GmbH**

The sample was supplied as being representative of the manufactured product, and it has been tested as Multipurpose Construction Adhesives in accordance with the relevant ISO 16000, AgBB, ISO 11890-1, ASTM D2369 and EPA method 24 testing standards (See test report no. 392-2017-00087601\_H\_EN, 392-2017-00087601\_D\_EN and 392-2017-10097401\_XD\_EN).

**The test results of the tested adhesive indicate that the product qualifies for LEED v4 specifications on VOC emissions and VOC content by complying with:**

**VOC emissions specifications in LEED EQ credit "Low-emitting products":**

- the requirements of DIBt (October 2010) and AgBB (February 2015), and the formaldehyde limit of 10 µg/m<sup>3</sup> after 28 days
- the requirements of CDPH-IAQ (California Department of Public Health); and a TVOC below 0.5 mg/m<sup>3</sup> in both office and class room.

**VOC content specifications in LEED EQ credit "Low-emitting products":**

- The requirements of SCAQMD rule 1168 (2005)

15 May 2017



\_\_\_\_\_  
Maria Pelle  
Chemist

LEED® is the preeminent program for the design, construction, maintenance and operations of high-performance green buildings. USGBC® and the related logo are trademarks owned by the U.S. Green Building Council and are used with permission.