

for HILTI MT modular support system in combination with X-BT threaded studs on steel

according to IEC / EN 61537, Section 11.1 ELECTRICAL CONTINUITY TEST

A series of tests¹ were conducted to determine the conductivity properties of the below designated HILTI MT channel system mounted with HILTI X-BT fastener on a corrosion protected carbon steel base. Installation built according Hilti installation recommendations.

Test criteria:

A Test over the splice/joint: The impedance (Z) shall not exceed 50 m Ω B Test over length of conduct. The impedance (Z) shall not exceed 5 m Ω /m

Test #	Measuring tip	Comment	Test criteria	Result ¹	Outcome
	position				
1	1-0	whole system to ground (worst case)	< 50 mΩ	0.43 mΩ	complying
2	1-3	cross member	< 5 mΩ/m	0.28 mΩ/m	complying
3	3-4	splice	< 50 mΩ	0.05 mΩ	complying
4	4-5	cross member	< 5 mΩ/m	0.21 mΩ/m	complying
5	5-0	splice	< 50 mΩ	0.05 mΩ	complying

¹) Averaged over tree test samples measured.

Test setup:

The test setup according to IEC / EN 61537, Section 11.1. The measurements were conducted with the 4-wire resistance measurement method.



The test samples were assembled from the following elements:

- I.-Channel MT-40D OC (500 mm)
- Bracket MT-BR-40 600 OC
- 4-hole Baseplate MT-B-O4 OC
- X-BT-MR M10/15 SN 8, ass. with twist-lock MT-TL M10 OC