




## KCM-MD Long Plate 3/8" + 1/2" + 5/8"


2285445-11.2024











Per FM approval, the metal plate of the insert must be on the top of the deck flutes. For seismic bracing applications cut tube flush to bottom of metal deck. \*Turn threaded rod until bottomed out to ensure full thread engagement.