



We hereby confirm that the

Hilti screw anchor HUS-I 6x55 M8/M10  
with M8/M10 stepped thread

in the version steel, galvanised,  
when used in accordance with European Technical Approvals

ETA-08/0307 or ETA-10/0005

complies with the guidelines of VdS Schadenverhütung GmbH, 50735 Cologne<sup>1)</sup>  
for fastening pipes  
up to DN 50 (connection with M8 anchor rod) and  
up to DN 100 (connection with M10 anchor rod)  
for water extinguishing systems to reinforced concrete substructures,  
e.g. concrete slabs.

Hilti Deutschland GmbH  
D-86916 Kaufering

ppa. Martin Reuter

Dipl.-Ing. Construction Sector SFI  
Head of Associations, Approvals

p.p. Michael Liebig

Dipl.-Ing. Construction Sector (FH)  
Product Manager Metal Anchors

<sup>1)</sup> VdS CEA 4001:2010-11:  
Guidelines for sprinkler systems, planning and installation, Section 15.2.4